

Oakland Township Southwest Water System Storage & Treatment

May 12, 2014

Introduction

This memorandum provides the cost opinions for design and construction of water treatment (iron removal) and storage improvements for the Southwest Water System in Oakland Township. Three different system conditions were reviewed for phasing the construction (existing, 20-year and ultimate development). The existing condition is derived from the 2012 billing data and the peaking factors for the maximum day in July. The 20-year condition was determined as part of the Water Reliability Study, January 2014. This 20-year population and demand are for the existing water service boundary. The ultimate design condition considers expanding the service area to allow for future development in the Southwest portion of the Township. These cost opinions are being provided for use in determining anticipated annual bond payments.

System Sizing

The 2012 billing data and peaking factors were used to determine the existing average day and maximum day demand. These values were used to calculate the size of the storage tank which is approximately equal to one average day volume in the Southwest Water System. The required treatment capacity is equal to the maximum day demand because storage will be provided to service the system during peak hour and fire protection.

Table 1: Water System Requirements

| Southwest Water System | | | | | | | | | |
|------------------------|------------|-------|-------------|-------|-------------|-------|----------------------------|-----------|-------|
| Condition | Population | REUs | Demand | | | | Required Storage (gallons) | Treatment | |
| | | | Average Day | | Maximum Day | | | (gpm) | (MGD) |
| | | | (gpm) | (MGD) | (gpm) | (MGD) | | | |
| Existing | 5,037 | 1,835 | 754 | 1.1 | 2537 | 3.7 | 1,100,000 | 2600 | 3.7 |
| 20 Year | 5,860 | 2,096 | 877 | 1.3 | 2952 | 4.3 | 1,250,000 | 3000 | 4.3 |
| Ultimate | 8,218 | 3,000 | 1230 | 1.8 | 4139 | 6.0 | 1,750,000 | 4200 | 6.0 |



The Southwest Water System’s maximum day peaking factor is higher than other comparable communities. This has a large impact on the cost of treatment. A graph of the data used to develop the peaking factor is provided in Figure 1. This graph shows that the high usage was seen for several days and is therefore not an overly conservative estimate. The high maximum day peaking factor is attributed to lawn watering.




Figure 1

The average day demand for the year 2012 based on billing records is 1.09 MGD. OHM reviewed daily demand for 16 days in 2012 in order to determine the maximum day peaking factor. Table 2 summarizes the observed data. As shown in Table 2 four days had a maximum day peaking factor greater than 3.0. The highest was 3.37 seen on July 2, 2012. This was the peaking factor used for the maximum day calculations in Table 1.



Table 2 Maximum Day Peaking Factors

| Date | Daily Use | | Peaking Factor |
|-----------|-----------|-------|----------------|
| | (gpm) | (MGD) | |
| 6/20/2012 | 2042 | 2.94 | 2.71 |
| 6/21/2012 | 1636 | 2.36 | 2.17 |
| 6/22/2012 | 1550 | 2.23 | 2.06 |
| 6/23/2012 | 1875 | 2.70 | 2.49 |
| 6/24/2012 | 1862 | 2.68 | 2.47 |
| 6/25/2012 | 1971 | 2.84 | 2.61 |
| 6/26/2012 | 2016 | 2.90 | 2.67 |
| 6/27/2012 | 2149 | 3.09 | 2.85 |
| 6/28/2012 | 2208 | 3.18 | 2.93 |
| 6/29/2012 | 2297 | 3.31 | 3.05 |
| 6/30/2012 | 2439 | 3.51 | 3.24 |
| 7/1/2012 | 2502 | 3.60 | 3.32 |
| 7/2/2012 | 2537 | 3.65 | 3.37 |
| 7/3/2012 | 1336 | 1.92 | 1.77 |
| 7/4/2012 | 1162 | 1.67 | 1.54 |
| 7/5/2012 | 1217 | 1.75 | 1.62 |

Costs

The construction cost opinions were prepared to allow for possible phasing of improvements. There is very little cost differential between existing conditions and 20 year existing system boundary demands and costs. There is a noticeable increase in demand when the water system boundaries are expanded to allow for future development in this area. Table 3 is a summary of the Southwest Water System improvement costs.

Table 3 Southwest Water System Improvement Costs

| Condition | REUs | Storage | Treatment | Total Annual Bond Payment | Annual Bond Payment / REU |
|-----------|-------|-------------|--------------|---------------------------|---------------------------|
| Existing | 1,835 | \$7,740,000 | \$10,588,000 | \$1,203,631 | \$656 |
| 20 Year | 2,096 | \$7,740,000 | \$10,853,000 | \$1,221,034 | \$583 |
| Ultimate | 3,000 | \$9,187,000 | \$12,752,000 | \$1,440,772 | \$480 |



Appendix A
Water Treatment Cost Opinions



Project Summary Engineer's Opinion of Probable Project Costs

Owner: Oakland County Water Resources Commissioner's Office
Project: _____
Work: Existing: 2,600 gpm (3.7 MGD) Iron Removal Treatment Plant to serve the Southwest Service Area in Oakland Township. Install Raw Water Transmission Main from Country Creek Well Houses to Water Treatment Facility.

Date: 4/18/2014
Project No.: 0105-13-0091
Prepared By: S. Wright
Reviewer: V. Putala
Current ENR: 9749.51

| Item No. | Item Description | Est. Quantity | Unit | Unit Price | Total Cost |
|-------------------------------------------|-----------------------------------------------------------------------|---------------|------|----------------|------------------------|
| 1 | Masonry Block Building | 4,100 | SF | \$200.00 | \$820,000.00 |
| 2 | Well Pump Bowl Assembly Modification | 4 | EA | \$28,000.00 | \$112,000.00 |
| 3 | Induced Draft Aeration (2,600 gpm) | 1 | LS | \$135,000.00 | \$135,000.00 |
| 4 | Concrete Cast-in-Place Detention Tank (85,000 gallons) | 500 | CY | \$650.00 | \$325,000.00 |
| 5 | High Service Pumps (1300 gpm) | 3 | EA | \$77,000.00 | \$231,000.00 |
| 6 | Variable Speed Drives for High Service Pumps | 3 | EA | \$27,000.00 | \$81,000.00 |
| 7 | Horizontal Pressure Filters (4 units @ 10 ft dia x 30' Long 1020 gpm) | 1 | LS | \$1,275,000.00 | \$1,275,000.00 |
| 8 | Backwash Water Tank | 1 | LS | \$148,000.00 | \$148,000.00 |
| 9 | Effluent Metering | 1 | LS | \$11,000.00 | \$11,000.00 |
| 10 | Chemical Feed Facilities | 1 | LS | \$97,000.00 | \$97,000.00 |
| 11 | Process Piping | 1 | LS | \$200,000.00 | \$200,000.00 |
| 12 | Valves | 40 | EA | \$6,500.00 | \$260,000.00 |
| 13 | Standby Emergency Power | 1 | LS | \$149,000.00 | \$149,000.00 |
| 14 | Mechanical Systems (5%) | 1 | LS | \$151,000.00 | \$151,000.00 |
| 15 | Electrical Systems (10%) | 1 | LS | \$318,000.00 | \$318,000.00 |
| 16 | Instrumentation (7%) | 1 | LS | \$245,000.00 | \$245,000.00 |
| 17 | Site Work (5%) | 1 | LS | \$228,000.00 | \$228,000.00 |
| 18 | 16-inch Raw Water Transmission Main | 4,400 | LF | \$250.00 | \$1,100,000.00 |
| 19 | Isolation Valves | 12 | EA | \$6,000.00 | \$72,000.00 |
| 20 | Site Water Main Modifications | 1 | LS | \$75,000.00 | \$75,000.00 |
| TRADES SUBTOTAL | | | | | \$6,033,000.00 |
| CONTRACTUAL REQUIREMENTS | | | | | |
| | General Conditions | 10% | | | \$603,300.00 |
| | General Requirements | 5% | | | \$301,650.00 |
| | Contingencies | 20% | | | \$1,206,600.00 |
| TOTAL CONSTRUCTION COST: | | | | | \$8,144,550.00 |
| PROJECT COSTS | | | | | |
| | Engineering | 25% | | | \$2,036,140.00 |
| | Finance and Legal | 5% | | | \$407,230.00 |
| ENGINEER'S OPINION OF PROJECT COST | | | | | \$10,588,000.00 |



Project Summary Engineer's Opinion of Probable Project Costs

Owner: Oakland County Water Resources Commissioner's Office
Project: _____
Work: 20-year: 3,000 gpm (4.3 MGD) Iron Removal Treatment Plant to serve the Southwest Service Area in Oakland Township. Install Raw Water Transmission Main from Country Creek Well Houses to Water Treatment Facility.

Date: 4/17/2014
Project No.: 0105-13-0091
Prepared By: S. Wright
Reviewer: V. Putala
Current ENR: 9749.51

| Item No. | Item Description | Est. Quantity | Unit | Unit Price | Total Cost |
|-------------------------------------------|-----------------------------------------------------------------------|---------------|------|----------------|------------------------|
| 1 | Masonry Block Building | 4,100 | SF | \$200.00 | \$820,000.00 |
| 2 | Well Pump Bowl Assembly Modification | 4 | EA | \$28,000.00 | \$112,000.00 |
| 3 | Induced Draft Aeration (3,000 gpm) | 1 | LS | \$150,000.00 | \$150,000.00 |
| 4 | Concrete Cast-in-Place Detention Tank (85,000 gallons) | 500 | CY | \$650.00 | \$325,000.00 |
| 5 | High Service Pumps (1500 gpm) | 3 | EA | \$86,000.00 | \$258,000.00 |
| 6 | Variable Speed Drives for High Service Pumps | 3 | EA | \$27,000.00 | \$81,000.00 |
| 7 | Horizontal Pressure Filters (4 units @ 10 ft dia x 34' Long 1020 gpm) | 1 | LS | \$1,350,000.00 | \$1,350,000.00 |
| 8 | Backwash Water Tank | 1 | LS | \$148,000.00 | \$148,000.00 |
| 9 | Effluent Metering | 1 | LS | \$11,000.00 | \$11,000.00 |
| 10 | Chemical Feed Facilities | 1 | LS | \$97,000.00 | \$97,000.00 |
| 11 | Process Piping | 1 | LS | \$200,000.00 | \$200,000.00 |
| 12 | Valves | 40 | EA | \$6,500.00 | \$260,000.00 |
| 13 | Standby Emergency Power | 1 | LS | \$149,000.00 | \$149,000.00 |
| 14 | Mechanical Systems (5%) | 1 | LS | \$157,000.00 | \$157,000.00 |
| 15 | Electrical Systems (10%) | 1 | LS | \$330,000.00 | \$330,000.00 |
| 16 | Instrumentation (7%) | 1 | LS | \$254,000.00 | \$254,000.00 |
| 17 | Site Work (5%) | 1 | LS | \$235,000.00 | \$235,000.00 |
| 18 | 16-inch Raw Water Transmission Main | 4,400 | LF | \$250.00 | \$1,100,000.00 |
| 19 | Isolation Valves | 12 | EA | \$6,000.00 | \$72,000.00 |
| 20 | Site Water Main Modifications | 1 | LS | \$75,000.00 | \$75,000.00 |
| TRADES SUBTOTAL | | | | | \$6,184,000.00 |
| CONTRACTUAL REQUIREMENTS | | | | | |
| | General Conditions | 10% | | | \$618,400.00 |
| | General Requirements | 5% | | | \$309,200.00 |
| | Contingencies | 20% | | | \$1,236,800.00 |
| TOTAL CONSTRUCTION COST: | | | | | \$8,348,400.00 |
| PROJECT COSTS | | | | | |
| | Engineering | 25% | | | \$2,087,100.00 |
| | Finance and Legal | 5% | | | \$417,420.00 |
| ENGINEER'S OPINION OF PROJECT COST | | | | | \$10,853,000.00 |



Project Summary Engineer's Opinion of Probable Project Costs

Owner: Oakland County Water Resources Commissioner's Office
Project: _____
Work: Ultimate Development: 4,200 gpm (6.0 MGD) Iron Removal Treatment Plant to serve the Southwest Service Area in Oakland Township. Install Raw Water Transmission Main from Country Creek Well Houses to Water Treatment Facility.

Date: 4/17/2014
Project No.: 0105-13-0091
Prepared By: S. Wright
Reviewer: V. Putala
Current ENR: 9749.51

| Item No. | Item Description | Est. Quantity | Unit | Unit Price | Total Cost |
|-------------------------------------------|----------------------------------------------------------------------|---------------|------|----------------|------------------------|
| 1 | Masonry Block Building | 5,000 | SF | \$200.00 | \$1,000,000.00 |
| 2 | Well Pump Bowl Assembly Modification | 4 | EA | \$28,000.00 | \$112,000.00 |
| 3 | New 500 gpm submersible well and pump | 1 | EA | \$150,000.00 | \$150,000.00 |
| 4 | Induced Draft Aeration (2,100 gpm) | 1 | LS | \$225,000.00 | \$225,000.00 |
| 5 | Concrete Cast-in-Place Detention Tank (85,000 gallons) | 500 | CY | \$650.00 | \$325,000.00 |
| 6 | High Service Pumps (1400 gpm) | 4 | EA | \$10,500.00 | \$42,000.00 |
| 7 | Variable Speed Drives for High Service Pumps | 4 | EA | \$27,000.00 | \$108,000.00 |
| 8 | Horizontal Pressure Filters (6 units @ 10 ft dia x 28' Long 840 gpm) | 1 | LS | \$1,875,000.00 | \$1,875,000.00 |
| 9 | Backwash Water Tank | 1 | LS | \$110,000.00 | \$110,000.00 |
| 10 | Effluent Metering | 1 | LS | \$11,000.00 | \$11,000.00 |
| 11 | Chemical Feed Facilities | 1 | LS | \$97,000.00 | \$97,000.00 |
| 12 | Process Piping | 1 | LS | \$300,000.00 | \$300,000.00 |
| 13 | Valves | 50 | EA | \$6,500.00 | \$325,000.00 |
| 14 | Standby Emergency Power | 1 | LS | \$149,000.00 | \$149,000.00 |
| 15 | Mechanical Systems (5%) | 1 | LS | \$191,000.00 | \$191,000.00 |
| 16 | Electrical Systems (10%) | 1 | LS | \$402,000.00 | \$402,000.00 |
| 17 | Instrumentation (7%) | 1 | LS | \$310,000.00 | \$310,000.00 |
| 18 | Site Work (5%) | 1 | LS | \$287,000.00 | \$287,000.00 |
| 19 | 16-inch Raw Water Transmission Main | 4,400 | LF | \$250.00 | \$1,100,000.00 |
| 20 | Isolation Valves | 12 | EA | \$6,000.00 | \$72,000.00 |
| 21 | Site Water Main Modifications | 1 | LS | \$75,000.00 | \$75,000.00 |
| TRADES SUBTOTAL | | | | | \$7,266,000.00 |
| CONTRACTUAL REQUIREMENTS | | | | | |
| | General Conditions | 10% | | | \$726,600.00 |
| | General Requirements | 5% | | | \$363,300.00 |
| | Contingencies | 20% | | | \$1,453,200.00 |
| TOTAL CONSTRUCTION COST: | | | | | \$9,809,100.00 |
| PROJECT COSTS | | | | | |
| | Engineering | 25% | | | \$2,452,280.00 |
| | Finance and Legal | 5% | | | \$490,460.00 |
| ENGINEER'S OPINION OF PROJECT COST | | | | | \$12,752,000.00 |



Appendix B

Water Storage Cost Opinions



Project Summary Engineer's Opinion of Probable Project Costs

Owner: Oakland County Water Resources Commissioner's Office
Project: _____
Work: Existing and 20-year: 500,000 gallons of storage at water treatment
and 750,000 gallons of storage in distribution system

Date: 4/17/2014
Project No.: 0105-13-0091
Prepared By: J. Patterson
Reviewer: V. Putala
Current ENR: 9749.51

| Item No. | Item Description | Est. Quantity | Unit | Unit Price | Total Cost |
|---------------------------------|----------------------------------------------------------|---------------|------|-------------------------------------------|-----------------------|
| 1 | Storage Tank located in distribution System | 750,000 | GAL | \$1.00 | \$750,000.00 |
| 2 | Storage Tank located adjacent to Water Treatment Phase I | 500,000 | GAL | \$1.00 | \$500,000.00 |
| 3 | Cathodic Protection | 2 | EA | \$30,000.00 | \$60,000.00 |
| 4 | Decorative Façade for Storage | 12,000 | SF | \$25.00 | \$300,000.00 |
| 5 | Site Piping and Valves | 1 | LS | \$250,000.00 | \$250,000.00 |
| 6 | Altitude Valve | 2 | EA | \$75,000.00 | \$150,000.00 |
| 7 | Booster Station | 2 | EA | \$800,000.00 | \$1,600,000.00 |
| 8 | Onsite Backup Generator | 2 | EA | \$100,000.00 | \$200,000.00 |
| 9 | Site Improvements | 1 | LS | \$150,000.00 | \$150,000.00 |
| 10 | Electrical Improvements | 1 | LS | \$250,000.00 | \$250,000.00 |
| 11 | System Controls | 1 | LS | \$150,000.00 | \$150,000.00 |
| 12 | Land Acquisition | 1 | LS | \$50,000.00 | \$50,000.00 |
| | | | | TRADES SUBTOTAL | \$4,410,000.00 |
| CONTRACTUAL REQUIREMENTS | | | | | |
| | General Conditions | 10% | | | \$441,000.00 |
| | General Requirements | 5% | | | \$220,500.00 |
| | Contingencies | 20% | | | \$882,000.00 |
| | | | | TOTAL CONSTRUCTION COST: | \$5,953,500.00 |
| PROJECT COSTS | | | | | |
| | Engineering | 25% | | | \$1,488,380.00 |
| | Finance and Legal | 5% | | | \$297,680.00 |
| | | | | ENGINEER'S OPINION OF PROJECT COST | \$7,740,000.00 |



Project Summary Engineer's Opinion of Probable Project Costs

Owner: Oakland County Water Resources Commissioner's Office
Project: _____
Work: Ultimate Development: 1,000,000 gallons of storage at the water treatment plant and 750,000 gallons of storage in distribution system

Date: 4/17/2014
Project No.: 0105-13-0091
Prepared By: J. Patterson
Reviewer: V. Putala
Current ENR: 9749.51

| Item No. | Item Description | Est. Quantity | Unit | Unit Price | Total Cost |
|---------------------------------|----------------------------------------------------------|---------------|------|-------------------------------------------|-----------------------|
| 1 | Storage Tank located in distribution System | 750,000 | GAL | \$1.00 | \$750,000.00 |
| 2 | Storage Tank located adjacent to Water Treatment Phase I | 1,000,000 | GAL | \$1.00 | \$1,000,000.00 |
| 3 | Mixing System | 1 | LS | \$150,000.00 | \$150,000.00 |
| 4 | Cathodic Protection | 2 | EA | \$30,000.00 | \$60,000.00 |
| 5 | Decorative Façade for Storage | 15,000 | SF | \$25.00 | \$375,000.00 |
| 6 | Site Piping and Valves | 1 | LS | \$300,000.00 | \$300,000.00 |
| 7 | Altitude Valve | 2 | EA | \$75,000.00 | \$150,000.00 |
| 8 | Booster Station | 2 | EA | \$800,000.00 | \$1,600,000.00 |
| 9 | Onsite Backup Generator | 2 | EA | \$100,000.00 | \$200,000.00 |
| 10 | Site Improvements | 1 | LS | \$200,000.00 | \$200,000.00 |
| 11 | Electrical Improvements | 1 | LS | \$250,000.00 | \$250,000.00 |
| 12 | System Controls | 1 | LS | \$150,000.00 | \$150,000.00 |
| 13 | Land Acquisition | 1 | LS | \$50,000.00 | \$50,000.00 |
| | | | | TRADES SUBTOTAL | \$5,235,000.00 |
| CONTRACTUAL REQUIREMENTS | | | | | |
| | General Conditions | 10% | | | \$523,500.00 |
| | General Requirements | 5% | | | \$261,750.00 |
| | Contingencies | 20% | | | \$1,047,000.00 |
| | | | | TOTAL CONSTRUCTION COST: | \$7,067,250.00 |
| PROJECT COSTS | | | | | |
| | Engineering | 25% | | | \$1,766,810.00 |
| | Finance and Legal | 5% | | | \$353,360.00 |
| | | | | ENGINEER'S OPINION OF PROJECT COST | \$9,187,000.00 |



Appendix C

Annual Bond Payment

WCWRC - Southwest District Water System User Costs

April 21th, 2014

Interest Rate (%)
Loan Duration (years)

| |
|-------|
| 2.75% |
| 20 |

User Cost Determination

| Project No. | (P) Amount Financed (\$) | i (%) | n (years) | $(1+i)^n$ | A $i*(1+i)^n$ | B $(1+i)^{n-1}$ | A/B | P*(A/B) Annual Debt (\$/yr) | Number of REUs | Annual Bond Payment per REU (\$/REU) | Total Annual Bond Payment per REU (\$/REU) |
|----------------------------------|-----------------------------------|----------|--------------|-----------|------------------|--------------------|---------|-----------------------------------|-------------------|-----------------------------------------------|--------------------------------------------------------|
| Existing Demand | | | | | | | | | | | |
| Water Treatment/Raw Transmission | \$10,588,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$695,332.28 | 1,835 | \$378.93 | |
| Water Storage | \$7,740,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$508,299.19 | 1,835 | \$277.00 | \$655.93 |
| 20- Year Demand | | | | | | | | | | | |
| Water Treatment/Raw Transmission | \$10,853,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$712,735.29 | 2,096 | \$340.05 | |
| Water Storage | \$7,740,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$508,299 | 2,096 | \$242.51 | \$582.55 |
| Ultimate Demand | | | | | | | | | | | |
| Water Treatment/Raw Transmission | \$12,752,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$837,446 | 3,000 | \$279.15 | |
| Water Storage | \$9,187,000 | 2.75% | 20 | 1.72043 | 0.04731 | 0.72043 | 0.06567 | \$603,326 | 3,000 | \$201.11 | \$480.26 |